




# Performance curves ALB EC 40/20 WW



- Heat output WW element ①-③ These diagrams show the heat output depending on the flow/ return/outside temp. over the air volume.
- Water volume WW element shows the water flow rate depending on the flow/return/outside temp. over the air volume.
- Pressure loss WW element shows the water throughflow over water pressure loss kPa.



#### (4) Water flow rate at 70/50 °C<sup>1)</sup>





# Reference

The integration of air filters ELF-ALB 40/20 F7 (ISO  $ePM_1$  50% (F7)) in intake air systems fulfils the requirements of VDI 6022.


Reference	Page
Planning information	14 ff.

# ① Heat output at temperature 80/60 °C





#### (5) Water pressure loss at 70/50 °C<sup>1)</sup>



Other accessories	Page
Silencers	494 ff.
Hydraulic unit details	492 ff.
Flexible ventilation ducts,	
ventilation grilles, fittings,	
shutters	561 ff.
Supply air disc valves	584 f.

# Fresh air box ALB EC WW backward curved, for rectangular ducts 40 x 20 cm

#### Accessories

#### Hydraulic unit

WHSH HE 24V (0-10V)No. 08318 For controlling the heat output of the warm water heating element in combination with room/duct sensors. Includes flow/return temperature display, pump, actuator, mixer valve, gravity brake, thermal cladding and flexible connection hoses.

### Replacement and pollen filter

- ISO Coarse 90% (G4) **ELF-ALB 40/20 G4** No. 07619 - Filter class ISO ePM<sub>10</sub> 70% (M5) **ELF-ALB 40/20 M5** No. 06766 - Filter class ISO ePM<sub>1</sub> 50% (F7) **ELF-ALB 40/20 F7** No. 06767 Large cassette filter for long cleaning intervals. Unit = 3 pcs.

#### Room sensor – Air quality AIR1/KWL-CO2 0-10V No. 20251 AIR1/KWL-FTF 0-10V No. 20252 For measuring the CO<sub>2</sub> concentration or relative from humidity.

For measuring the  $CO_2$  concentration or relative room humidity. Maximum total of one sensor can be connected. Dim. mm (W x H x D) 85 x 85 x 27

#### Room sensor - Temperature

**TFR-ALB/KWL** Ref. no. 07277 For measuring the room temperature and controlling the ventilation unit according to the setpoint. Incl. 20 m control line.

Dim. mm (W x H x D) 80 x 80 x 25

# Connection cable – 20 metres long

ALB EC-SK 20 Ref. no. 06816 – 40 metres long

ALB EC-SK 40 Ref. no. 06817 Attach between ALB and control element as well as between ALB and TFR-ALB/KWL.

## Transition piece – Symmetrical

ALB-ÜS 40/20 Ref. no. 07617 From unit flange to round duct systems.

#### Flexible connecting sleeve

**FM 250** Ref. no. 01672 For acoustic decoupling, incl. 2 pcs. hose clamps.

## Angle flange ring

**FR 250** Ref. no. 01203 Made of galvanised steel sheet, for duct connection.

#### Duct shutter, motorised

**RVM 250** Ref. no. 02576 Prevents cold draughts when the unit is at a standstill. Automatic function through fan operation, with mounted spring return motor. Installation in any position, closing force adjustable corresponding to fan power and installation position.









